

Fire Risk Assessment - Priory Water Sports Centre

HAZARD	PERSONS AT RISK	PRECAUTIONS & CONTROL MEASURES	Risk Value	Further Action
Fire Fighting equipment	All	Ensure that firefighting equipment is maintained	Low	Checks as required and update equipment
Fire Spreading	All Property Damage	Ensure that combustible materials are not stored in corners or under stairs etc	Low	Monitoring
Fire Spreading	All	Ensure that the fire fighting equipment remains accessible	Medium	Monitoring
Detection	All	It should be noted that the building does not have a fire detection system or alarm system to notify people of a fire within the building	Medium	Fire awareness notices to be put up at various locations
Electrical	All	Ensure that the Landlord electrical systems are checked at a minimum of every 5 years	Low	Monitoring & records
Rubbish	All	Ensure that rubbish is not allowed to accumulate and bins are emptied And that rubbish is not allowed to accumulate under the stairs	Low	Monitoring
Fuel Store and decanting fuel	All	Fuel to be decanted from the fuel jerry cans to the safety boats away from the store area Funnel to be used rather than a free pour	Low	On Going monitoring
Fuel in Jerry Cans	All	These are to be kept in fuel store Minimum amounts of fuel may be stored in the fuel tanks of the boats but no additional fuel is to be stored in the boat garage	Low	Monitoring
Fuel in Jerry Cans	All	On hot days and if the can is full pressure can build up inside of the Jerry Can. Careful opening of the can is required to ensure that the fuel does not spray out	Med	Training & Monitoring

Boat Fire	All & property Damage	Fuel when decanted to boat fuel tanks should be done outside of the boat and in open area.	Low	Monitoring
Fuel Store	All	Ensure that no smoking takes place within the vicinity	Medium	Monitoring

Version 2.0

Revision 4

Last Reviewed August 2024

PSC Commodore